

ANALYTICAL LABORATORIES, INC. (ALI)  
 4208 Bethlehem Pike  
 Telford, PA 18969  
 (215) 723-6466  
 PA DEP ID# 09-00332

SAMPLE ANALYSIS REPORT

Customer: Lower Makefield Township  
 1550 Oxford Valley Rd.  
 Yardley, PA 19067

Date sampled : 08/29/21  
 Date received: 08/29/21  
 Time sampled : 1200  
 Sampled by : CD

Attn: 267-274-1103 Lynn Todd

email:

Water Classification: The level of coliform bacteria was below the requirement for pool water, therefore the pool water at the time of sampling meets the Bucks County Health Department standards for this parameter.

ANALYTICAL RESULTS

<u>Sample Number</u>	<u>Sample Source</u>	<u>Total Coliform Bacteria, count/100ml</u>	<u>HPC count/ml</u>	<u>Total Chlorine, mg/l</u>	<u>pH, units</u>
10580-21A	Olympic Pool	< 1	< 1	3.9	7.9
10580-21B	Lap Pool	< 1	< 1	2.7	7.5
10580-21C	Intermediate Pool	< 1	< 1	2.6	7.3
10580-21D	Tot Pool	< 1	< 1	6.2	7.5

Parameter	Analysis Method	QL	Analysis Date/Time
pH, units	SM4500HB	1.0	08/29/21 1200
Total Chlorine, mg/l	SM4500ClG	0.05	08/29/21 1200
Total Coliform Bacteria, count/100ml	SM9222B	1	08/29/21 1627
Heterotrophic Plate Count (HPC), count/ml	SM9215B	1	08/29/21 1555

Symbol key:

- < - less than
- > - greater than
- mg/l - milligram/liter
- ml - milliliter
- QL - Quantitation Limit

*Geo. W. Kinka*  
 \_\_\_\_\_  
 Geoff W. Kinka/Manager