

ANALYTICAL LABORATORIES, INC. (ALI)
 4208 Bethlehem Pike
 Telford, PA 18969
 (215) 723-6466
 PA DEP ID# 09-00332

SAMPLE ANALYSIS REPORT

Customer: Lower Makefield Township
 1550 Oxford Valley Rd.
 Yardley, PA 19067

Date sampled : 06/05/22
 Date received: 06/05/22
 Time sampled : 1325
 Sampled by : CD

Attn: 267-274-1103 Lynn Todd
 CAdams@LMT.org
 email: LTodd@LMT.org

Sample Location: Lower Makefield Twp. Pools
 1050 Edgewood Rd.
 Yardley, PA

Water Classification: The level of coliform bacteria was below the requirement for pool water, therefore the pool water at the time of sampling meets the Bucks County Health Department standards for this parameter.

ANALYTICAL RESULTS

<u>Sample Number</u>	<u>Sample Source</u>	<u>Total Coliform Bacteria, count/100ml</u>	<u>HPC count/ml</u>	<u>Total Chlorine, mg/l</u>	<u>pH, units</u>
9259-22A	Olympic Pool	< 1	< 1	3.0	7.4
9259-22B	Lap Pool	< 1	< 1	3.2	7.4
9259-22C	Intermediate Pool	< 1	< 1	0.5	7.6
9259-22D	Tot Pool	< 1	< 1	5.1	7.5

<u>Parameter</u>	<u>Analysis Method</u>	<u>QL</u>	<u>Analysis Date/Time</u>
pH, units	SM4500HB	1.0	06/05/22 1325
Total Chlorine, mg/l	SM4500ClG	0.05	06/05/22 1325
Total Coliform Bacteria, count/100ml	SM9222B	1	06/05/22 1703
Heterotrophic Plate Count(HPC), count/1ml	SM9215B	1	06/05/22 1623

Symbol key:

- < - less than, > - greater than
- mg/l - milligram/liter
- ml - milliliter
- QL - Quantitation Limit



 Geoff W. Kinka/Manager